



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7300-0785:0506
CATEGORY:	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
LISTEE:	Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL, 34243 Contact: Conover, Thomas (941) 487-2336 Email: thomasconover@Eaton.com
DESIGN:	<p>Model INC-PS10 Intelligent Notification Controller. Models INC-CPU Replacement CPU/LCD Module, INC-PS10-ELEC Replacement Motherboard with Power Supply, and INC-CAB1-DOOR Replacement Cabinet Door. Models SUB-NAC Addressable NAC Module, EOLR-1K End of Line Resistor, and EOLR-10K End of Line Resistor.</p> <p>The model INC-PS10 (INC) is a NAC booster supply with 4 inputs and 4 power outputs, and also includes 4 external relays (1 common trouble, the other 3 programmable). The model SUB-NAC is a pass through device that includes an integral isolator circuit that supervises two outputs that can isolate shorts individually. The subassembly models INC-CPU, INC-PS10-ELEC, and INC-CAB1-DOOR are field replaceable assemblies for already installed INC-PS10 units. The end of line resistors model EOLR-1K is a 1K ohm EOLR for the INC outputs and model EOLR-10K is a 10K ohm EOLR for the SUB-NAC outputs.</p> <p>Refer to listee's data sheet for additional detailed product description and operational considerations.</p>
RATING:	<p>Model INC-PS10:</p> <p>Primary Operating Supply: 120 VAC, 60 Hz, 4 A</p> <p>Secondary Operating Supply: 24 VDC</p> <p>Model SUB-NAC:</p> <p>18.5-24 VDC</p>
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details. Models complies with the applicable requirements in UL 864, 10th Edition.
NOTES:	

7-19-22 VWW



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 05/01/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division