



NOTES:-

1. MAINS INPUT MUST BE WYE 3 PHASE 4WIRE + GROUND, PROVIDED BY OTHERS.
2. ALL AC POWER CABLING IS 3 PHASE 4 WIRE + GROUND AT 380/400/415V AC.
3. POWER WIRING AND CONTROL WIRING SHOULD BE IN SEPERATE CONDUITS.
4. CABLING PROVIDED BY OTHERS.
5. INSTALLATION MUST COMPLY WITH NATIONAL AND LOCAL CODES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF AMERICAN POWER CONVERSION AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM APC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

TITLE: SILCDN UPS 480KW
SYSTEM WIRING DIAGRAM
480KW, 380/400/415V AC, 1MDD.
PROJECT: SUBMITAL DRAWING SHEET 1 OF 1

DWG NO.: SL480KHC1-WD
DRAWN: BALAMURUGAN 09/04/01
CHECKED: M SAILOKHE 09/04/01
ENGINEER: OMIRUD/S WASH 09/04/01

REV. 1
SCALE: NTS
PROJECTION:

