3 Port Solenoid Valve Direct Operated Poppet Type **VK300 Series**Rubber Seal



Universal porting

Available for N.C. valve, N.O. valve, divider valve, selector valve, etc.

C: 0.80 dm3/(s.bar)

(Passage $2 \rightarrow 3$)

Compact: Width 18 x Length 63 (mm)
Low power consumption

4 W DC (Standard type)


2 W DC (Low wattage type)

Suitable for use in vacuum applications –101.2 kPa Suitable for use in copper-free applications

The portions that come in contact with fluids do not contain copper, thus enabling the standard product to be used as is.



Base mounted



Specifications

Specifications	
Type of actuation	Direct operated type 2 position single solenoid
Fluid	Air
Ambient and fluid temperature	−5 to 50°C (No freezing)
Response time (at 0.5 MPa) (1)	10 ms or less (Standard), 15 ms or less (Low power consumption type)
Manual override	Non-locking push type
Lubrication	Not required (Use turbine oil Class 1 ISO VG32, if lubricated.)
Mounting orientation	Unrestricted
Impact/Vibration resistance(2)	300/50 m/s ²
Enclosure	Dustproof

Note1) Based on dynamic performance test, JIS B 8419: 2010. (Coil temperature: 20°C, at rated voltage, without surge suppressor)

Note2) Impact resistance: No malfunction occurred when it is tested with a drop tester in the axial direction and at the right angles to the main valve and armature in both energized and de-energized states every once for each condition. (Values at the initial period)

Vibration resistance: No malfunction occurred in a one-sweep test between 45 and 2000 Hz. Test was performed at both energized and de-energized states in the axial direction and at the right angles to the main valve and armature. (Values at the initial period)

Solenoid Specifications

o o lo li o poo								
Electrical entry			Grommet (G), DIN terminal (D)					
Rated voltage (V)		AC	100, 110, 200, 220, 240					
nateu voltage (v)		DC	12, 24					
Allowable voltage fluc	tuation		±10% of rated voltage					
	Standard	Inrush	9.5 VA/50 Hz, 8 VA/60 Hz					
Apparent power (AC) *	type	Holding	7 VA/50 Hz, 5 VA/60 Hz					
Apparent power (AO)	Continuous	Inrush	3.5 VA/50 Hz, 3.3 VA/60 Hz					
	duty type	Holding	3 VA/50 Hz, 2.8 VA/60 Hz					
Dawar aanaumutian (DC) *	W/o indicator light	4 W (Standard), 2 W (Low power consumption type)					
Power consumption (DC)	W/ indicator light	4.3 W (Standard), 2.3 W (Low power consumption type)					
Curre vellere curre		AC	Varistor					
Surge voltage suppre	SSOF	DC	Diode (Varistor for 12 VDC or less)					
Indicator light		AC	Neon bulb					
indicator light		DC	LED					

^{*} At the rated voltage

Flow Rate Characteristics/Weight

	T Hate GHaracte															
								Flov	rate ch	naracteri	stics					Weight (g)
		Operating	Port size	$1 \rightarrow 2 (P \rightarrow A)$			$2 \rightarrow 3 (A \rightarrow R)$			3 →	2 (R -	A)	2 –	weight (g)		
	Valve model	range (MPa)		C [dm³/ (s·bar)]	b	Cv	C [dm³/ (s·bar)]	b	Cv	C [dm³/ (s·bar)]	b	Cv	C [dm³/ (s·bar)]	b	Cv	Grommet
ъ	VK332			0.47	0.44	0.13	0.47	0.40	0.13	0.48	0.47	0.14	0.47	0.44	0.13	
ported	VK332Y (For low wattage, 2 W DC)	0 to 0.7	M5 x 0.8	0.41	0.27	0.10	0.39	0.35	0.10	0.41	0.38	0.11	0.38	0.40	0.10	80
	VK332E (Continuous duty type)			0.41	0.27	0.10	0.39	0.35	0.10	0.41	0.38	0.11	0.38	0.40	0.10	
Body	VK332V (For vacuum)	-101.2 kPa		0.47	0.44	0.13	0.47	0.40	0.13	0.48	0.47	0.14	0.47	0.44	0.13	
	VK332W (Low wattage, vacuum)	to 0.1		0.41	0.27	0.10	0.39	0.35	0.10	0.41	0.38	0.11	0.38	0.40	0.10	
mounted sub-plate)	VK334			0.85	0.26	0.19	0.80	0.27	0.19	0.83	0.26	0.20	0.76	0.41	0.20	
불후	VK334Y (For low wattage, 2 W DC)	0 to 0.7		0.65	0.24	0.15	0.55	0.32	0.14	0.65	0.15	0.14	0.41	0.63	0.14	
윤 옆	VK334E (Continuous duty type)		1/8	0.65	0.24	0.15	0.55	0.32	0.14	0.65	0.15	0.14	0.41	0.63	0.14	120
Base (With 8	VK334V (For vacuum)	-101.2 kPa		0.85	0.26	0.19	0.80	0.27	0.19	0.83	0.26	0.20	0.76	0.41	0.20	
88	VK334W (Low wattage, vacuum)	to 0.1		0.65	0.24	0.15	0.55	0.32	0.14	0.65	0.15	0.14	0.41	0.63	0.14	

Mounting with VK300

The VK300 series can be mounted on the manifold base VV5K3 of VK 3000 series. Refer to page 1422 for details.



VV061 VV100

V100 S070


VQD-V

VK VT

How to Order


Note) AC-type models that are CE-compliant have DIN terminals only.





Construction





Component Parts

No.	Description	Material	Note
1	Body	Aluminum die-casted	Platinum silver
2	Cover	Resin	Black
3	End cover	Resin	Black
4	Spool valve assembly	Aluminum, NBR	
5	Return spring	Stainless steel	
6	Molded coil	Resin	Black

VK300 Series

Manifold Specifications



Specifications

	1 : 1 : 1 : 1 : 1		_	_
i iping memou	Common SUP, Individual EXH	Body ported		
Piping method	Common SUP, Common EXH	Body ported, Base mounted		
Valve stations		1 to 20		

00N NPT


00T NPTF


Note) For 9 stations or more, supply air both sides of P port. The common exhaust type should exhaust from both of the R port.

Note) CF-compliant: For DIN terminal only


Common SUP/Common EXH









CE-compliant Nil CE-compliant Note) Applicable only for DIN terminal type










Applicable solenoid valve VK334□-□□□(-Q) Applicable blanking plate assembly VK300-42-1A **Bracket** VK300-43-1A CE-compliant


> Q CE-compliant Note) Applicable only for DIN terminal type







How to Order



thread type

00T NPTF


00F G 00N NPT

Rc

Applicable solenoid valve VK334□-□□□(-Q)

Applicable blanking plate assembly VK300-42-1A


Type S42 (Solenoids on the same side of A port)




١	port		C6	ø6 cassette]	N	NPT
						Т	NPT
'n	alve	stations					
	01	1 station					
		1					
	20	20 stations					

+ CE	=	compliant
Nil		_
Q		CE-compliant
Note)		pplicable only fo
	D	IN terminal type

Common SUP/Individual EXH





How to Order	——
VV3K3 - 21 - 05	
Valve stations •	P, R port

Valve stations • 1 station 20 20 stations

Applicable solenoid valve
VK332□-□□□-M5(-Q)
VK332□-□□□-01(-Q)

Applicable blanking plate assembly VK300-42-1A

· CE-	compliant
Nil	_
Q	CE-compliant
Note) A	onlicable only fo

DIN terminal type

VV061 VV100

V100

S070 VQD


VOD-V ٧K


VT

Combinations of Solenoid Valve, Manifold Gasket and Manifold Base









Applicable base

VV3K3-20 (-Q) 21 (-Q) VV5K3-20 (-Q) 21 (-Q) Manifold base

Applicable base

VK300-45-1 Sub-plate VV3K3-40 (-Q) (S) 42 (-Q) VV5K3-40 (-Q) Manifold base

(S) 41 (-Q) (S) 42 (-Q)

Caution

Mounting Screw

Mounting Screw Tightening Torques M3: 0.6 N·m

Body ported Base mounted


Manifold gasket and screw assembly VK300-41-1A VK300-41-2A

Note1) Mounting direction is fixed, do not mount on opposite side.

Note2) The VK300 series can be mounted on the manifold base VV5K3 of VK 3000 series. Refer to page 1422 for details.

Combinations of Blanking Plate Assembly and Manifold Base

Blanking plate assembly: VK300-42-1A







Applicable base: In common for all types of VV3K3 models


3 Port Solenoid Valve Direct Operated Poppet Type VK300 Series

Dimensions: Body Ported



Dimensions: Base Mounted





DIN terminal: VK334-□D-01

VQD VOD-V

٧K VT

Refer to grommet type for other dimensions.


13.5 13

34

Type 20 Manifold/Body Ported (Top ported)

VV3K3-20- Stations

n1 = Number of VK300



L Dimens	sion																		n: St	ations
n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L ₁	35	54	73	92	111	130	149	168	187	206	225	244	263	282	301	320	339	358	377	396
L2	27	46	65	84	103	122	141	160	179	198	217	236	255	274	293	312	331	350	369	388
L3	13	32	51	70	89	108	127	146	165	184	203	222	241	260	279	298	317	336	355	374

Type 21 Manifold/Body Ported (Top ported)

VV3K3-21- Stations


48.5

n x Rc 1/8

(R port)

P=19 19

n1 = Number of VK300



Applicable cable O.D: ø3.5 to ø7 78.4 70.9 Pg7 2 x Rc 1/8 (P port) 6

L Dimension n: St															tations					
n	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L ₁	38	57	76	95	114	133	152	171	190	209	228	247	266	285	304	323	342	361	380	399
12	27	46	65	84	103	122	141	160	179	198	217	236	255	274	203	312	331	350	369	388

VV061

VV100 V100

S070


VQD

VOD-V ٧K


VT

Type 40 Manifold/Base Mounted (Bottom ported)

VV3K3-40- Stations -01




DIN terminal: D Applicable cable O.D: ø3.5 to ø7 83.4 75.9 Pg7 4 x Rc 1/8 (P, R port)




L Dimension n: Stations L₁ L₂ Lз


Type 42 Manifold/Base Mounted (Side ported)

VV3K3-42- Stations -01






Built-in One-touch fitting: VV3K3-42-Stations -C4, C6



Refer to the above drawing for DIN terminal dimensions.

Refer to the above drawing for other dimensions.

Solenoid at A port side: VV3K3-S42-Stations - □



Manual override
(Non-locking)

OCE

TO A RE 1/8

(Pitch)

Party 1920

(A port)

VK VT

Ln	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
L1	38	57	76	95	114	133	152	171	190	209	228	247	266	285	304	323	342	361	380	399
L2	28	47	66	85	104	123	142	161	180	199	218	237	256	275	294	313	332	351	370	389

VV061

VV100 V100

S070

VQD

VOD-V



VK300 Series Specific Product Precautions

Be sure to read this before handling the products.

Refer to back page 50 for Safety Instructions and pages 3 to 9 for 3/4/5 Port Solenoid Valve Precautions.

⚠ Caution

How to Wire DIN Terminal

Connection

- Loosen the set screw and pull out the connector from the terminal block of the solenoid.
- Remove screw and insert screwdriver into the slit area near the bottom of terminal block to separate block and housing.
- 3. Loosen the terminal screws (slotted screws) on the terminal block, insert the core of the lead wire into the terminal, and attach securely with the terminal screws.
- 4. Tighten the ground nut to secure the cable.

▲ Caution

Use caution in wiring because it will not meet the IP65 (enclosure) standard if you use the other cable than prescribed heavy-duty cable of size (03.5 to 07).

Tighten the ground nut and set screw within the specified range of torque.

Change of electrical entry (Orientation)

After separating terminal block and housing, the cable entry direction can be changed by attaching the housing in the desired direction (4 directions in 90 increments).

In the case of w/ indicator light, avoid damaging the light with lead wire.


Precautions

Plug a connector in or out vertically, never at an angle.

Applicable cable O.D.: ø3.5 to ø7

(Reference)

0.5 mm² 2 core and 3 core wires equivalent to JIS C 3306



Connector part no.: VK300-82-1

 Part no. of connector with indicator lig 								
	Voltage symbol	Part no.						
100 VAC	100V	VK300-82-2-01						
110 VAC	110V	VK300-82-2-03						
200 VAC	200V	VK300-82-2-02						
220 VAC	220V	VK300-82-2-04						
240 VAC	240V	VK300-82-2-07						
6 VDC	6V	VK300-82-4-51						
12 VDC	12V	VK300-82-4-06						
24 VDC	24VD	VK300-82-3-05						
48 VDC	48VD	VK300-82-3-53						

Circuit with indicator light

AC circuit diagram

NL: Neon bulb






24 VDC or more

LED: Light emitting diode D: Protective diode C D: Light emitting diode

⚠ Caution

Light/Surge Voltage Suppressor



Precautions on connection of 24 V or more DC Grommet type should be connected as following; Red lead wire for (+) side, Black lead wire for (-) side respectively.

With the DIN terminal, connect the positive (+) side to the connector's no. 1 terminal, and the negative (-) side to the no. 2 terminal. [Refer to the marks on the terminal board.]

 For 12 VDC or below, there is no positive (+) or negative (-) directionality.

⚠ Warning

Valve Mounting Direction

When mounting a valve on the manifold base or sub-plate, etc., the mounting orientation is already decided. If mounted in a wrong direction, the equipment to be connected may result in malfunction. Refer to pages 1413 to 1417 for external dimensions in mounting.

Vacuum Spec. Type: VK33□V (VK33□W)

In contrast to the standard product, this vacuum specification valve has less air leakage at low pressures, a feature that should be taken into consideration when using this valve for vacuum applications.

⚠ Caution

 Since this valve has slight air leakage, it can not be used for holding vacuum (including positive pressure holding) in the pressure container.

Continuous Duty Type: VK33□E

Recommended for continuous duty with long time loading.

- This model is for continuous duty, not for high cycle rates. But even in low cycle rates, if energizing the valve more than once a day, please consult with SMC.
- 2. Energizing solenoid should be done at least once in 30 days.

How to Calculate the Flow Rate

For obtaining the flow rate, refer to front matter.

